

An Integrated Data-Driven Framework for Smart Home and Microgrid Energy Management: Combining Genetic Optimization, Big Data Analytics, and Adaptive Sensor Networks

A synthesis of research on PV–battery operation, microgrid energy management, big data analytics, and machine-learning-based sensor energy savings

**Ritu Rajendra Mahajan, Vaishnavi Dnyaneshwar Palve, Abhijeet Ananda Sawant,
Prajwal Pavan Sevalkar, Mrs. Nilima Bhamare, Mrs. Vishakha Chavan**

Department of Electrical Engineering

Guru Gobind Singh College of Engineering & Research Centre, Nashik

vaishnavidpalve@gmail.com, nilusawant.52@gmail.com, vishakha.chavan2620@gmail.com

Abstract: *Smart homes and microgrids increasingly combine photovoltaic (PV) generation, battery energy storage, grid exchange, controllable loads, and Internet-connected sensors. Managing these components together is challenging because solar generation and demand vary over time, grid supply may be interrupted, battery operation is constrained, and sensor data can be noisy or costly to transmit. This paper synthesizes four research directions: genetic-algorithm-based home energy management under on-grid and off-grid conditions; microgrid energy-management architectures and optimization methods; big data analytics and its data-quality challenges; and machine-learning-based energy saving in wireless sensor networks (WSNs). Based on this synthesis, a conceptual integrated framework is proposed. The framework combines data acquisition and quality control, weather and load forecasting, adaptive sensor selection and sampling, and multi-objective scheduling of PV, batteries, grid power, and flexible loads. A constrained optimization formulation is provided for cost, unmet demand, grid dependence, battery degradation, and emissions. The paper does not claim new experimental validation; instead, it defines an implementable architecture and a reproducible evaluation plan. The central conclusion is that energy scheduling and sensing should be designed as coordinated functions: reliable decisions require trustworthy data, while sensing and communication should consume only the energy necessary to preserve decision quality.*

Keywords: Smart home; microgrid; energy management system; photovoltaic (PV) generation; battery energy storage; genetic algorithm; big data analytics; adaptive sensing; wireless sensor network (WSN); machine learning; demand-side management; forecasting; multi-objective optimization

I. INTRODUCTION

The transition toward distributed energy resources has increased the importance of local energy management. A microgrid can coordinate distributed generation, storage, and loads while operating connected to the utility grid or in islanded mode. Such coordination can improve resilience and local use of renewable energy, but it requires decisions under operational limits and uncertainty [1]. At household level, PV generation is intermittent and demand changes through the day. Batteries can shift energy across time and provide backup during outages, but their charging state, power limits, and lifetime must be respected [2].



Intelligent energy management depends on more than the scheduling algorithm. Sensors measure energy use, environmental conditions, battery status, and equipment states. These measurements may be incomplete, noisy, delayed, or expensive to collect and transmit. Big data analytics offers tools to process large, heterogeneous streams, but introduces challenges involving volume, velocity, variety, veracity, variability, value, storage, privacy, and security [3]. In parallel, adaptive WSN research shows that energy can be saved by selecting only useful sensor nodes and adjusting sampling rates and transmission intervals while preserving quality of service (QoS) [4].

The four source papers address complementary parts of this problem, but they do not jointly validate a single end-to-end system. This paper therefore contributes a structured synthesis and a proposed integration architecture rather than presenting a new tested algorithm. The goal is to connect sensing, data management, prediction, and energy scheduling in one coherent research design.

The motivation for this integration is strengthened by the changing role of residential consumers. Homes increasingly behave as active energy nodes: they may generate electricity through rooftop photovoltaics, store surplus energy, shift selected loads, and exchange power with the utility. When several such resources are coordinated at the community or microgrid level, decisions made for one device can affect network demand, reserve availability, and resilience during disturbances. An effective controller must therefore balance household-level objectives with wider system constraints rather than optimize electricity cost in isolation.

Several practical uncertainties complicate this task. Solar output depends on cloud cover and weather forecasts; household demand depends on occupancy, appliance use, and time of day; tariffs and grid availability may change; and battery performance depends on state of charge, power limits, temperature, and ageing. A controller that relies on perfect forecasts or uninterrupted communication may perform poorly in real deployments. The proposed design consequently treats forecast confidence, measurement freshness, and fallback operation as explicit inputs to decision-making.

The central research question is how optimization, data analytics, and adaptive wireless sensing can be coordinated so that an energy-management system remains economical, reliable, and aware of its own data limitations. The objectives are to (1) define a modular architecture for household and microgrid energy flows, (2) connect data validation and short-horizon prediction to constrained scheduling, (3) adapt sensor activity without disabling safety-critical measurements, and (4) specify a reproducible evaluation plan. These objectives are design goals to be tested in future implementation, not claims of measured performance.

II. REVIEW OF RELATED RESEARCH

2.1 Genetic-algorithm-based home energy management

Thabet, Ibrahim, and Abu-Samah present a home energy management system for a hybrid PV–battery–grid configuration, considering both grid-connected and outage conditions [1]. Their genetic algorithm allocates energy across daily time periods while considering operating cost, load coverage, and grid dependence. The reported MATLAB simulation uses Iraqi climate data and sunny/cloudy scenarios. The paper reports 0% unmet load, a 91.96% reduction in total energy cost, a 93.49% reduction in grid dependency, and a decrease in loss of power supply probability from 33% to 4% under the studied conditions [1]. These are results from that study's specific model and scenarios, not results of the integrated framework proposed here.

2.2 Microgrid energy management

Ahmethodžić, Mušić, and Huseinbegović review microgrid energy management, including centralized and decentralized structures, optimization methods, storage, demand-side management (DSM), and electric vehicles [2]. They describe energy management as a multi-objective, constrained problem. Typical goals include reducing operating and fuel costs, emissions, power losses, and load shedding while maintaining safe and reliable operation. Constraints may include generator limits, storage charge/discharge limits, voltage and frequency limits, and grid-exchange requirements. The review also highlights renewable forecast uncertainty and the need for real-time validation. This supports a layered design in which scheduling is informed by forecasts and constrained by physical operating limits.



2.3 Big data analytics

Amalina and colleagues review big data analytics techniques and applications, including text, visual, voice, video, network, and geospatial analytics [3]. Their discussion of the “six Vs” identifies volume, velocity, variety, veracity, variability, and value as key characteristics; complexity is also discussed. Tools such as Hadoop, Spark, and MapReduce, alongside programming and analytics platforms, can support large-scale data processing. For an energy-management system, the transferable lesson is not that every deployment needs a distributed big-data platform, but that data volume, timeliness, heterogeneity, quality, and privacy should be considered explicitly when choosing the data pipeline.

2.4 Machine-learning-based energy saving in WSNs

Kang and colleagues propose a two-phase WSN energy-saving framework adapted to environmental states [4]. Their network-level phase selects a small sensor subset using a hybrid filter-wrapper feature-selection method. Their node-level phase adjusts sampling rates and transmission intervals using simulated annealing while preserving QoS. Experiments using real-world smart-home sensor data are reported in the source paper. The approach suggests that an energy-management system can save sensing and communication energy without simply disabling sensors indiscriminately: sensor selection and sampling must be conditioned on environmental context and prediction quality.

2.5 Synthesis and research gap

Taken together, the papers indicate four complementary needs: (i) optimize energy allocation across PV, batteries, loads, and grid exchange; (ii) handle microgrid constraints and islanding; (iii) maintain a reliable data pipeline for heterogeneous, time-varying measurements; and (iv) reduce sensor-network energy use without undermining the quality of decisions. The integration gap addressed in this paper is architectural: how to coordinate these functions, define their interfaces, and evaluate their combined behavior. The source papers do not establish that one integrated implementation already achieves the numerical benefits reported individually.

A comparison across the four studies reveals differences in scope and evidence. The home-energy study focuses on scheduling a specific hybrid PV–battery–grid system and reports simulation outcomes under defined scenarios [1]. The microgrid review provides a broader classification of control structures, objectives, and operating constraints, but it does not prescribe one universally best optimization method [2]. The big-data review addresses the management and analysis of diverse data streams at a general level [3], while the WSN study concentrates on reducing sensing and communication expenditure through context-aware node selection and sampling [4]. These contributions are complementary because they operate at different layers of the overall system.

The methods also have different dependencies. Genetic algorithms can explore nonlinear scheduling choices but may require careful parameter tuning and can have variable computation time. Centralized microgrid control can coordinate resources using a common view of the system, but it depends on communications and a reliable central controller; decentralized approaches can improve local autonomy but require coordination among agents. Big-data platforms can support scalable processing, although their complexity may be unnecessary for a small home installation. Adaptive WSN methods can reduce data traffic, but only if the selection process preserves the measurements needed for accurate forecasts and safe control.

For this reason, the proposed integration does not assume that every technique must be deployed in its most computationally intensive form. A small residential installation may use a local gateway, a lightweight database, and a modest optimizer, whereas a campus or community microgrid may require distributed storage, stream processing, and multiple coordinated controllers. The architecture is designed to scale by function: data quality checks, forecasting, optimization, sensor management, and safety supervision remain distinct modules even when they run on the same hardware.

The principal unresolved issue is the interaction between these modules. Existing individual studies provide useful methods, but the reviewed evidence does not by itself establish how adaptive sensing affects forecast errors, how those errors influence battery scheduling, or how the complete system behaves during outages and communication failures.



The proposed research addresses this gap by defining common interfaces and a shared evaluation protocol. This synthesis is a foundation for implementation and comparative testing, rather than a substitute for such testing.

III. PROPOSED INTEGRATED FRAMEWORK

The proposed framework has five interacting layers.

Layer 1 — Sensing and actuation. Smart meters, PV inverters, battery-management systems, weather sensors, and selected WSN nodes provide measurements. Actuators control battery charging/discharging, flexible loads, and grid exchange where the hardware and local rules permit.

Layer 2 — Data ingestion and quality management. Measurements are timestamped, checked for missing or implausible values, normalized to consistent units, and tagged with source and quality status. Short gaps may be handled using a documented imputation method; longer gaps should trigger a confidence flag or fallback policy rather than silently creating false precision. Access control, encryption, retention limits, and audit logs are included because energy and occupancy data can reveal sensitive behavior [3].

Layer 3 — Forecasting and environmental-state estimation. Historical PV output, weather observations, load profiles, tariff information, and sensor context are used to estimate short-horizon PV generation and demand. Environmental states may be clustered or classified so that the sensor subset and sampling policy can change with conditions, following the adaptive principle in [4]. Forecast uncertainty should be passed to the scheduler rather than represented only by a single point estimate.

Layer 4 — Coordinated optimization. A genetic algorithm or another suitable constrained optimizer schedules energy resources over a rolling horizon. It receives forecasts, battery state of charge (SOC), device limits, tariff signals, grid availability, and critical-load requirements. The optimizer selects energy flows and flexible-load schedules subject to physical and operational constraints [1], [2].

Layer 5 — Monitoring and feedback. The system compares predicted and measured performance, tracks battery SOC and sensor QoS, and records cost, renewable self-consumption, grid dependence, unmet load, communications use, and forecast errors. If the optimizer fails, data are stale, or communication is lost, a rule-based safe operating mode takes over. Human operators should be able to inspect why a decision was made.

The key integration principle is that sensor policies and energy schedules must be co-designed. A lower sampling rate can reduce communications energy, but it may make a load forecast less accurate. Conversely, excessive sensing can waste energy and bandwidth. The sensor manager should therefore preserve measurements that materially affect safety, critical-load coverage, battery constraints, or the optimizer's decision quality.

Information flows through the layers in a closed loop. Raw observations first receive timestamps, units, source identifiers, and quality flags. The forecasting module then produces expected PV generation and demand together with uncertainty indicators. The sensor manager uses the importance of each variable, recent forecast error, environmental state, and device energy cost to recommend a sampling policy. The scheduler receives both the forecast and its confidence, then generates a feasible plan. After commands are applied, measured outcomes are compared with predictions and the next cycle is updated.

A practical implementation can separate the control process into three time scales. Fast local protection operates continuously or at the device's native control rate and is never dependent on a cloud service. The supervisory energy scheduler runs periodically—for example, every few minutes or at a tariff-relevant interval—and updates battery and flexible-load targets. Slower analytics processes review historical performance, detect recurring patterns, and recalibrate forecasts or sensor policies. The actual interval should be selected according to hardware capabilities, tariff resolution, system dynamics, and communication reliability.

Coordination is handled through explicit data contracts. Each measurement should include a value, unit, timestamp, source, and quality status; each forecast should include a horizon and uncertainty estimate; and each proposed command should include a target, validity period, constraint checks, and reason code. Modules should reject stale or



out-of-range information rather than silently treating it as valid. When the central optimizer is unavailable, local controllers should maintain essential loads and enforce battery and inverter limits using a documented fallback policy. The framework supports multiple deployment topologies. In a single home, all non-safety modules may run on a local energy-management gateway. In a community microgrid, forecasting and data aggregation may be shared while device protection remains local. Where privacy is important, occupancy-related data can be processed locally and only aggregate or necessary features passed to higher-level services. These alternatives preserve the same functional interfaces while allowing the implementation to reflect cost, scale, privacy, and resilience requirements.

Integrated Smart Home and Microgrid Energy-Management Architecture




Figure 1. Proposed architecture linking sensing, data quality, forecasting, optimization and feedback.

IV. RESEARCH METHODOLOGY

Evaluation measures. Report total electricity cost, peak grid import, renewable self-consumption, unmet energy, critical-load coverage, loss-of-power-supply probability, battery throughput, SOC violations, forecast MAE/RMSE, data latency, missing-data rate, sensing energy, communication volume, and QoS. The framework should only be described as superior if measured results support that conclusion.

Proposed validation plan. Future validation should compare four baselines under identical PV, demand, tariff, battery, and outage traces: grid-first operation; fixed-rule PV-priority control; genetic-algorithm scheduling without adaptive sensing; and the full integrated framework. Tests should include sunny and cloudy days, rapid weather changes, peak demand, low state of charge, grid outages, missing data, and sensor or communication faults.

Synthesis procedure. First, common system inputs and operating constraints were identified. Second, the methods were mapped into sensing, data quality, forecasting, optimization, actuation, and feedback layers. Third, a common power-balance and battery-state model was written to express the interfaces between layers. Fourth, data-quality and adaptive-sensing requirements were added so scheduling decisions account for measurement reliability and communication cost. **Source selection and extraction.** The synthesis focuses on the four uploaded papers addressing genetic-algorithm-based PV–battery home energy management, microgrid energy-management methods and constraints, big-data analytics challenges, and machine-learning-based energy savings in wireless sensor networks. Their objectives, methods, limitations, and reported findings were grouped by system function.



Research design. This study uses a structured literature-synthesis and conceptual-design method. Four source papers are compared to identify complementary methods for home energy scheduling, microgrid control, big-data processing, and energy-aware wireless sensing. The result is an integrated architecture and an evaluation plan, not a claim of a newly tested system.

V. SYSTEM DESIGN

Security and maintainability. Use authenticated devices, encrypted communication where supported, role-based access, protected configuration, audit logs, and bounded data retention. Separate safety-critical control from non-critical analytics, and version forecasts, optimizer settings, and data-cleaning rules to make results reproducible.

Interfaces and outputs. Inputs include PV power, demand, tariff, weather, grid status, battery SOC, device ratings, and sensor-quality indicators. Outputs include battery charge/discharge commands, grid import/export targets, flexible-load schedules, sensor sampling rates, and an operational log. Each command should carry a timestamp, validity interval, and reason code.

Control hierarchy. A day-ahead layer can plan flexible-load timing and reserve targets. A rolling-horizon layer updates the plan as measurements and forecasts change. A fast local safety layer handles battery limits, grid disconnection, stale data, and communication failure. When the optimizer is unavailable or its output is infeasible, the system falls back to a documented rule-based policy.

Software and data layer. A local time-series store receives timestamped measurements with units, validity ranges, quality flags, and source identifiers. A preprocessing module checks missing, delayed, or implausible values. Forecasting estimates near-term PV output and demand. The optimizer proposes a schedule, and a supervisory controller checks it against hard safety constraints before sending commands.

Hardware layer. The minimum prototype includes a PV inverter or PV-generation data feed, a battery and battery-management system (BMS), a bidirectional grid meter, load meters, a grid-availability signal, a controller or edge computer, and environmental sensors. Critical protection and BMS measurements must remain active regardless of adaptive-sensing decisions.

Design objective. The design coordinates local energy supply, storage, flexible demand, and grid exchange while maintaining reliable measurements and safe operation during grid-connected and islanded conditions.

Hardware configuration. A representative prototype can include a smart meter or circuit-level meter, a PV inverter with a supported monitoring interface, a battery-management system, controllable loads or smart plugs, environmental sensors, a wireless sensor gateway, and a local controller. Hardware selection must be based on electrical ratings, protocol compatibility, manufacturer limits, and local electrical codes. The design does not assume that all devices expose writable control interfaces; read-only devices can still support monitoring and forecasting.

Software modules. The gateway should provide device adapters, a time-series store, data-quality checks, a forecasting service, an optimization service, a sensor-policy manager, a command validator, and an audit interface. Modules can communicate through documented APIs or a message broker. The implementation should record software versions, model parameters, optimizer settings, tariff assumptions, and data-cleaning rules so that experiments can be repeated. Distributed tools such as stream-processing frameworks should be introduced only when the data rate or number of devices justifies their operational overhead.

Control and safety design. The optimizer proposes a schedule; a separate command-validation layer checks it against inverter ratings, battery charge/discharge limits, minimum and maximum SOC, grid connection status, load priorities, and any applicable export restrictions. Device-level protection remains authoritative. If forecasts are stale, the solver times out, or communication is lost, the controller should switch to a conservative local policy, preserve critical loads where possible, and avoid commands that could violate equipment limits. Manual override and a clear indication of fallback mode should be available to operators.

Data model and timing. All records should use a consistent time basis and explicit units—for example, power in kW, energy in kWh, and SOC as a fraction or percentage. Sampling intervals should be stored with each record because



values collected at different rates cannot be compared safely without alignment. The design should distinguish measured values from estimates and forecasts, and retain provenance for imputed or filtered values. A late measurement should not overwrite a newer observation without a documented reconciliation rule.

Verification and commissioning. Before closed-loop control is enabled, verify sensor calibration, timestamp alignment, battery telemetry, command permissions, communication-loss behavior, and emergency-stop or manual-override procedures. Begin in monitoring-only mode, compare the proposed schedule with actual operation, and then enable limited control after constraints and fallback behavior are demonstrated. Commissioning records should include test cases, expected responses, observed results, and unresolved issues. These steps reduce the risk of confusing a promising simulation with a safe deployable controller.

VI. SYSTEM MODEL AND OPTIMIZATION FORMULATION

Consider a discrete scheduling horizon $t = 1, \dots, T$, with time step Δt . Let $P_{pv,t}$ be available PV power, $P_{load,t}$ the household or microgrid demand, $P_{bat,ch,t}$ and $P_{bat,dis,t}$ the battery charging and discharging powers, $P_{grid,in,t}$ grid import, and $P_{grid,out,t}$ grid export. Let u_t indicate whether the utility grid is available. A simplified power balance is:

$$P_{pv,t} + P_{bat,dis,t} + P_{grid,in,t} + P_{short,t} = P_{load,t} + P_{bat,ch,t} + P_{grid,out,t}$$

where $P_{short,t}$ represents unmet demand (load shedding) and should be zero for critical loads whenever feasible. If the grid is unavailable, grid import and export are constrained to zero. The formulation can be expanded to include generators, electric vehicles, reactive power, network losses, and multiple microgrids when the application requires them [2].

Battery state of charge evolves as:

$$SOC(t+1) = SOC(t) + [\eta_{ch} P_{bat,ch,t} - P_{bat,dis,t} / \eta_{dis}] \Delta t / E_{bat}$$

where η_{ch} and η_{dis} are charging and discharging efficiencies and E_{bat} is nominal battery energy capacity. SOC must remain within prescribed minimum and maximum bounds, and charging/discharging powers must respect hardware ratings. A binary mode variable or equivalent constraint prevents simultaneous charging and discharging. Battery degradation may be approximated by a cycle-throughput penalty when a detailed electrochemical model is unavailable; the approximation must be disclosed.

A multi-objective cost function can be expressed as:


$$J = \sum_t [w_1 C_{grid,t} + w_2 P_{short,t} + w_3 G_{grid,t} + w_4 D_{bat,t} + w_5 E_{carbon,t} + w_6 L_{flex,t}]$$

Here $C_{grid,t}$ is the net grid-energy cost, $G_{grid,t}$ represents grid dependence, $D_{bat,t}$ is a battery-use/degradation proxy, $E_{carbon,t}$ represents emissions, and $L_{flex,t}$ is a penalty for discomfort or deviation from preferred flexible-load schedules. The weights $w_1 \dots w_6$ express priorities and must be selected transparently. An alternative is Pareto optimization, which avoids hiding trade-offs in a single weighted score. Critical-load penalties should be much larger than ordinary comfort penalties, but finite weights do not replace explicit safety constraints.

The optimizer's decision vector may include battery charge/discharge status, grid import/export, and the start time or power level of flexible loads for each time interval. A genetic algorithm can encode these decisions as chromosomes, evaluate fitness using the objective and constraint penalties, and apply selection, crossover, and mutation. Infeasible solutions should be repaired or penalized consistently. A rolling-horizon approach updates the schedule when new measurements arrive, forecasts change, or the grid state changes. This formulation is a proposed synthesis; it is not claimed to reproduce the exact equations or implementation of [1].



Simplified Power-Flow Model



$$\text{Power balance: PV} + \text{battery discharge} + \text{grid import} + \text{shortfall} = \text{load} + \text{battery charge} + \text{grid export}$$

Figure 2. Simplified power-flow representation for PV, storage, utility exchange and unmet demand.

VII. ADAPTIVE SENSING AND DATA ANALYTICS

The sensor manager operates alongside, rather than inside, the energy optimizer. At each update, it estimates the environmental state and ranks sensors by their incremental value for prediction or control. Sensors required for protection, battery management, metering, and critical-load monitoring are treated as mandatory. Other sensors may be sampled less frequently or temporarily omitted if the resulting information loss remains within a predefined tolerance. A conceptual sensor-selection objective is:

$$\text{minimize } \alpha N_s + \beta E_{\text{sense}} + \gamma E_{\text{comm}} + \delta LQoS$$

where N_s is the number of active non-mandatory sensors, E_{sense} is sensing energy, E_{comm} is communication energy, and $LQoS$ measures degradation in prediction or classification performance. Constraints require critical variables to remain observable and QoS to exceed a minimum threshold. This adapts the network-level and node-level ideas in [4] to an energy-management context, but the exact objective and constraints must be calibrated to the hardware and application.

Big-data methods should be selected proportionally to deployment scale. A single home may use a local time-series database and lightweight analytics; a campus or multi-microgrid deployment may require distributed stream processing. Regardless of platform, the pipeline should address six practical questions: How much data are produced? How quickly must they be processed? Which formats and sources are involved? How trustworthy are measurements? How does data flow vary? And what actionable value does each data stream provide? These questions translate the six-V framework in [3] into engineering requirements.

A practical data contract should define for every measurement its unit, timestamp, valid range, sampling interval, quality flag, retention policy, and responsible component. Forecasts should include an uncertainty indicator. The scheduler should be able to distinguish measured, estimated, stale, and unavailable values. These distinctions are essential during outages, sensor faults, or communication interruptions.

Sensing policy objectives. The sensing layer should balance measurement usefulness, communication cost, node energy, and the consequences of missing a reading. Measurements are not equally important: battery state of charge, inverter status, grid-availability signals, and critical-load conditions are safety- or feasibility-relevant and should be retained at their required protection rate. Less critical environmental or occupancy features may be sampled less



frequently when conditions are stable. Adaptive sensing must never disable built-in equipment protection or replace a certified battery-management system.

Context-aware sampling. A sensor-policy manager can consider recent variability, forecast error, changes in operating mode, communication quality, and the expected effect of a measurement on the next schedule. During stable operation it may reduce the reporting frequency of non-critical nodes; during rapid PV ramps, unexpected load changes, islanding, or low battery reserve it should increase observation frequency. Each change should have minimum and maximum sampling intervals, a hysteresis rule to avoid rapid toggling, and a record explaining why the policy changed.

Data validation and preparation. Before analytics, measurements should be checked for missing timestamps, duplicate records, impossible values, unit mismatches, stale readings, and sudden changes inconsistent with equipment ratings. Filtering should not erase genuine events such as a rapid load start or PV drop. Missing values may be flagged or imputed for forecasting, but imputed values must remain distinguishable from measurements and should not be used to satisfy safety-critical constraints. Time alignment and consistent units are necessary before comparing demand, PV output, battery power, and tariffs.

Analytics and feedback. Short-horizon forecasts of demand and PV output can support scheduling, while historical data can reveal recurring peaks, device-level patterns, and systematic prediction errors. Model performance should be monitored because household routines, weather, and equipment can change. If uncertainty increases or recent errors exceed a defined threshold, the system should widen reserve margins, use a conservative schedule, or temporarily increase sampling. The resulting measurements are then used to assess whether the action reduced cost or improved reliability.

Privacy and data governance. Fine-grained electricity and occupancy-related measurements can reveal household routines. The implementation should collect only variables needed for control, restrict access by role, protect communications where supported, and set a justified retention period. Local processing can reduce unnecessary transfer of sensitive raw data. Research exports should be minimized or de-identified where feasible, with access and processing decisions documented.

VIII. OPERATING PROCEDURE

The proposed control loop is as follows:

1. Acquire measurements from PV, battery, meters, grid-status signals, weather services, and the currently active sensor subset.
2. Validate data, detect missing or implausible values, and attach confidence and freshness flags.
3. Estimate environmental state and update short-horizon forecasts of PV generation and demand.
4. Select the sensor subset and sampling/transmission schedule for the next interval, while keeping safety-critical sensing active.
5. Generate a candidate energy schedule using the optimizer and enforce SOC, power, grid-availability, and load-priority constraints.
6. Apply only the first control action, then observe the system response and re-optimize at the next interval.
7. Log outcomes and compare forecasts with actual values; if data or optimization are unreliable, invoke the safe fallback controller.

The schedule should use a day-ahead or longer-horizon plan for decisions such as flexible-load timing and reserve targets, with a faster real-time layer for disturbances and outages. This is consistent with the distinction between long-term scheduling and short-term dispatch discussed in the microgrid review [2].



Proposed Operating Flowchart




Figure 3. Proposed operating flowchart, including validation, constrained scheduling and fallback control.

Step 1—Initialize and validate. At startup, identify available devices, load configuration and tariff data, synchronize clocks, check sensor status, and read battery and inverter limits. Confirm that all safety-critical signals are fresh. If critical inputs are missing, remain in monitoring or fallback mode rather than issuing unverified commands.

Step 2—Acquire and clean data. Collect PV generation, demand, battery state, grid status, weather, tariff, and flexible-load availability. Attach timestamps, units, source identifiers, and quality flags. Reject malformed records, mark stale measurements, and align observations to the scheduling interval without disguising missing data.

Step 3—Forecast and assess uncertainty. Estimate demand and PV generation over the chosen horizon. Compare forecasts with recent actual values and record prediction errors. When uncertainty is high, increase reserve requirements or use conservative assumptions instead of relying on a single optimistic forecast.



Step 4—Update sensing policy. Keep required protection and critical-state measurements at their prescribed rates. For non-critical sensors, adjust sampling according to variability, uncertainty, communication cost, and decision sensitivity. Apply rate limits and hysteresis, and log the reason for every material change.

Step 5—Optimize and validate the schedule. Generate battery charge/discharge targets, grid import/export plans, and flexible-load schedules subject to power balance, SOC bounds, equipment ratings, grid status, and load priorities. A separate validator must reject infeasible commands. If the solver fails or exceeds its allowed runtime, use the documented fallback policy.

Step 6—Apply, monitor, and learn. Send only validated commands to devices that support control. Verify command acknowledgement where available and compare actual outcomes with the planned schedule. Record cost, grid exchange, battery cycling, unmet load, forecast error, sensor traffic, and any fallback event. Use these records to tune models and thresholds under controlled change management.

IX. EVALUATION METHODOLOGY

Because this paper is a synthesis and conceptual design, no new simulation or field experiment is claimed. A future implementation should compare the integrated framework against clearly specified baselines: (A) grid-first supply; (B) fixed-rule PV-priority dispatch; (C) GA-based PV–battery scheduling without adaptive sensing; and (D) the full proposed framework. Use identical demand, weather, tariff, PV, battery, and outage traces across baselines.

Test at minimum sunny, cloudy, rapidly changing weather, high-demand, low-battery, and grid-outage scenarios. If possible, use multiple seasons and a range of battery capacities. Include forecast errors and missing or delayed sensor data. A simulation should report its time step, system capacities, SOC limits, efficiencies, tariffs, GA population size, generation count, crossover and mutation rates, stopping criteria, and random seeds so results can be reproduced.

Recommended metrics are:

- Economic: total energy cost, peak grid import, and cost per unit of served load.
- Reliability: unmet energy, critical-load coverage, loss of power supply probability, and outage recovery behavior.
- Renewable utilization: PV self-consumption, renewable fraction, and curtailed PV energy.
- Storage: SOC violations, charge/discharge throughput, and a clearly defined degradation proxy.
- Data and sensing: forecast MAE/RMSE, missing-data rate, latency, sensor energy, communication volume, and QoS.
- Robustness: performance under forecast error, communication loss, sensor faults, and abrupt grid changes.

The primary hypothesis is that the integrated design can reduce sensing overhead while preserving enough information for effective scheduling. This must be tested through ablation studies: disable adaptive sensing, disable forecasting, and replace GA with a rule-based scheduler one component at a time. Report confidence intervals or repeated-run distributions for stochastic optimizers. Numerical improvements should only be stated after these experiments are completed.

Experimental design. Evaluate the proposed architecture first in offline replay or simulation, then in hardware-in-the-loop testing, and only later in a limited live pilot. Compare the integrated approach with clearly defined baselines, such as a rule-based controller, a fixed-sampling policy, and an optimizer without adaptive sensing. Use identical load, PV, tariff, battery, and weather inputs across comparable runs. Separate tuning data from evaluation data to reduce optimistic bias.

Operating scenarios. Include ordinary grid-connected operation, high and low PV production, evening demand peaks, rapid cloud-driven PV changes, high tariffs, low battery SOC, communication delay, missing sensor readings, optimizer timeout, and grid outage/islanding where the equipment and test environment support it. Test typical and stressful cases, and state assumptions for islanded operation rather than treating it as automatically available.

Metrics. Economic performance can be measured by energy cost and peak grid import; energy performance by PV self-consumption and grid import/export; storage impact by battery throughput and equivalent cycling; reliability by unmet critical load and time spent in fallback mode; sensing performance by packet count, communication energy, missing-



data rate, and sensor-node lifetime; and prediction quality by MAE or RMSE for load and PV forecasts. Include computation time and constraint violations to show whether schedules can be produced in time and remain feasible. Ablation and sensitivity analysis. Remove one module at a time—adaptive sensing, forecasting, or the selected optimizer—to estimate its contribution. Vary battery capacity, forecast error, sampling limits, tariff structure, and communication loss. Report multiple runs for stochastic optimizers, including central tendency and spread, and describe parameter settings. Do not attribute improvement to the integrated architecture unless the comparison is controlled and measured results support it.

Reporting and reproducibility. Document dataset sources, time resolution, missing-data treatment, tariff assumptions, battery efficiency and SOC limits, optimizer parameters, forecast model, random seeds where applicable, and hardware/software versions. Report adverse outcomes as well as improvements. As this paper is a conceptual synthesis, these metrics and scenarios are proposed evaluation criteria, not experimental results produced by the present study.

X. PRACTICAL IMPLEMENTATION GUIDANCE

The following staged plan is recommended for translating the conceptual framework into a reproducible prototype. These are proposed engineering steps, not results reported by the four source papers.

Stage 1 — Instrumentation and baseline: connect the PV inverter, smart meter, battery-management system and grid-status signal. Confirm units, timestamps, sampling rates and safe operating limits before enabling automated control.

Stage 2 — Data and forecasting: store time-series measurements locally, track missing-data and latency rates, and establish simple persistence or moving-average forecasts as baselines before testing more complex models.

Stage 3 — Scheduling in simulation: test the power-balance and state-of-charge constraints offline. Use identical weather, demand, tariff and outage traces for every baseline, and fix random seeds for stochastic optimization runs.

Stage 4 — Shadow mode and controlled deployment: first run the optimizer without issuing commands and compare its recommendations with the existing controller. Enable limited control only after safety checks, operator review and fallback behavior have been tested.

Stage 5 — Ongoing validation: monitor reliability, cost, renewable utilization, battery throughput, forecast error, sensor energy and communication load. Reassess thresholds when equipment, tariffs, climate or occupancy patterns change.

A staged rollout reduces integration risk. Phase A is a read-only audit of meters, inverter data, battery telemetry, tariffs, and communication protocols. Phase B runs data-quality checks and forecasts without controlling devices. Phase C compares proposed schedules with actual operation in shadow mode. Phase D enables limited control for selected flexible loads or battery targets after command validation and fallback behavior have passed tests. Phase E expands scope only after reviewing reliability, cybersecurity, and operator feedback.

Interoperability and maintainability. Prefer documented protocols and stable device interfaces, and isolate manufacturer-specific details in adapters. Use configuration files for device ratings, tariff periods, and load priorities rather than embedding them in algorithm code. Version the configuration and retain a change log. Monitoring should show sensor freshness, optimizer status, battery limits, grid mode, active schedule, and fallback state so operators can diagnose failures.

Cybersecurity and operational ownership. Use unique credentials, least-privilege access, secure updates, encrypted links where supported, and segmented networks for control devices. Disable unused services and keep an inventory of firmware and software dependencies. Define who can change setpoints, acknowledge alarms, update models, and restore service after failure. A technically correct controller still requires clear responsibility for maintenance and incident response.

Practical acceptance criteria should be set before the pilot. Examples include zero violations of hard battery/inverter constraints during test cases, correct fallback

behavior under loss of communication, bounded command latency, acceptable forecast error, and a documented process for manual override. Economic or energy-saving targets should be established from the site baseline rather than assumed in advance. Pilot results should be reviewed before the system is allowed to control more devices.



Implementation item	Minimum requirement	Why it matters
Safety constraints	SOC bounds, inverter ratings, grid-islanding rules, critical-load priorities	Prevents unsafe or infeasible actions
Data quality	Timestamp, unit, range check, freshness and quality flag for each signal	Avoids decisions based on stale or invalid measurements
Fallback control	Defined rule-based mode for optimizer failure or communication loss	Maintains service when advanced functions fail
Reproducibility	Fixed traces, parameter log, random seeds and baseline definitions	Makes comparisons repeatable and auditable
Cybersecurity	Authentication, least-privilege access, encryption and signed updates	Reduces risk from sensitive data exposure or unauthorized control
Human oversight	Decision logs, alarm thresholds and operator override	Supports accountability and safe commissioning

XI. DISCUSSION

The proposed integration has several potential benefits. First, coupling PV–battery scheduling with grid-state awareness can support operation during both normal connection and islanded conditions [1], [2]. Second, explicit data-quality handling reduces the risk that an optimizer acts on stale or misleading measurements [3]. Third, adaptive sensing may extend sensor lifetime and reduce network traffic while maintaining QoS [4]. Finally, a modular architecture supports gradual deployment: a simple local controller can be introduced first, with forecasting and distributed analytics added only when they provide measurable benefit.

The design also faces trade-offs. Genetic algorithms can be computationally expensive and do not guarantee a global optimum. Forecast errors can lead to poor charging decisions, especially during sudden weather changes. A weighted objective can conceal conflicts between cost, emissions, reliability, and user comfort. Adaptive sensing can miss events if sampling is reduced too aggressively. Centralized control may simplify global optimization but create communication and single-point-of-failure concerns; decentralized or hierarchical control can improve local autonomy but requires coordination and consistent constraints [2]. These limitations favor a layered implementation with explicit safety rules, uncertainty-aware scheduling, and fallback operation.

Privacy and cybersecurity are system requirements, not optional add-ons. Fine-grained load and sensor traces can reveal occupancy and routines. Data minimization, local processing where practical, authentication, encryption, signed updates, and controlled access should be considered from the design stage. Real-world evaluation is also necessary: results from simulations or one climate region should not be assumed to transfer unchanged to another tariff structure, climate, household, or microgrid.

Before deployment, define critical and flexible loads; verify sensor calibration and timestamps; document battery and inverter limits; validate grid-connected and islanded behavior; test communication loss and stale data; confirm safe fallback actions; protect user data; and retain logs sufficient to reproduce decisions. A pilot should begin in monitoring or advisory mode before automatic control is enabled.

Deployment checklist. Deployment checklist.

Forecast errors can be managed with uncertainty margins, reserve targets, and frequent re-optimization. Sensor faults require quality flags and safe fallback rules. Battery wear should be reflected in the objective or in a transparent throughput limit. Cybersecurity risks call for authenticated access, encryption, update management, and least-privilege permissions. Computation time can be controlled by limiting the optimization horizon, warm-starting where possible, or using a simpler fallback policy when deadlines are missed.

Key challenges and mitigations. Key challenges and mitigations.



The integrated design may improve renewable self-consumption, cost-aware scheduling, outage preparedness, visibility of system performance, and sensing efficiency. These are expected benefits based on the combined design principles, not guaranteed results. They must be measured against baseline controllers using the same input traces and constraints. Potential benefits. Potential benefits.

A community system can coordinate several buildings and shared resources. A hierarchical design can keep local safety controls independent while exchanging schedules or power targets at the supervisory level. Islanding procedures, protection coordination, and grid-code compliance must be engineered separately; an energy scheduler does not replace protection or voltage/frequency control.

Community microgrids. Community microgrids.

A larger deployment can coordinate HVAC, lighting, EV charging, rooftop PV, and storage. Aggregated meters and building-management systems can provide data, while a supervisory controller schedules flexible loads around occupancy, demand peaks, and tariffs. Larger deployments may benefit from stream processing, but platform complexity should match the actual data rate and scale.

Commercial buildings and campuses. Commercial buildings and campuses.

The framework can schedule household appliances, improve the use of rooftop PV, manage battery reserves, and reduce avoidable grid purchases. User comfort and appliance constraints should be represented explicitly so that savings do not come at the cost of unacceptable service.

Residential buildings. Residential buildings.

The integrated design is valuable because the modules exchange information that is often treated separately. Forecast uncertainty can influence reserve decisions; sensor importance can influence sampling frequency; and actual schedule outcomes can inform later forecasts and thresholds. This creates a feedback loop in which the system evaluates not only energy performance but also the quality and timeliness of the information supporting each decision.

The main trade-off is between richer information and the cost of obtaining it. More frequent sensing can improve responsiveness but consumes node energy and bandwidth; more complex forecasting and optimization may improve flexibility but can increase computation time and maintenance burden. The appropriate balance depends on installation size, communication reliability, tariff complexity, and the consequences of a control error. A modular design permits simpler algorithms for small homes and more advanced tools for larger microgrids.

A second trade-off concerns centralized coordination and local resilience. A central scheduler can coordinate storage and loads across a site, but it can become a point of failure. Local controllers and a conservative fallback policy preserve basic operation when connectivity is interrupted, while the central layer resumes optimization when reliable inputs return. Safety-critical constraints should therefore be enforced locally and independently of high-level analytics.

The evidence base should be interpreted carefully. The source studies motivate individual components, but this synthesis does not establish a quantified end-to-end benefit for their combination. Any claim that integration reduces cost, extends sensor lifetime, or improves resilience must be demonstrated in controlled experiments against suitable baselines. The contribution at this stage is the explicit architecture, interfaces, failure handling, and evaluation plan.

XII. PRACTICAL APPLICATIONS, BENEFITS, AND CHALLENGES

This scenario is illustrative, not a measured case study. Actual decisions depend on system capacity, local tariff rules, user preferences, battery limits, forecast quality, and applicable electrical-safety requirements.

Consider a home with rooftop PV, a battery, essential appliances, and a utility connection that may occasionally fail. At the start of each scheduling interval, the controller reads PV output, household demand, battery state of charge (SOC), tariff, and grid status. It checks whether measurements are current and credible, then forecasts near-term generation and demand. The optimizer may charge the battery when solar generation exceeds immediate demand, preserve stored energy when an outage is likely, or shift a flexible appliance to a lower-tariff period. If the grid becomes unavailable, grid exchange is set to zero and the controller prioritizes essential loads. The next interval uses fresh measurements to revise the plan.



Residential buildings. In a home with rooftop PV and a battery, the controller can schedule flexible loads around solar availability and tariffs, monitor battery reserve, and improve visibility into household demand. It should preserve user comfort and appliance constraints and should not shift critical medical or safety-related loads without explicit design and consent.

Community microgrids and campuses. A shared controller can coordinate buildings, storage, PV, and flexible demand to reduce coincident peaks and manage local constraints. Different buildings may have different ownership, privacy, and priority requirements, so the architecture should expose transparent rules for allocation and override. Islanded operation is possible only when the electrical design, inverter capability, protection scheme, and operating procedures support it.

Commercial and remote sites. Small commercial facilities, telecom sites, and remote installations may benefit from coordinated storage, renewable generation, and load prioritization, particularly where energy cost or supply interruptions are significant. In these cases, reliability targets and reserve requirements may be more important than maximizing short-term self-consumption.

Potential benefits. The design may support better use of local renewable generation, lower avoidable peak imports, improved visibility of energy flows, and reduced wireless traffic from non-critical sensors. It may also provide traceable scheduling decisions and more consistent fallback behavior. These are expected benefits to be verified for each site; the magnitude depends on baseline demand, equipment, tariff, forecast quality, and control constraints.

Challenges and responses. Heterogeneous device protocols can be addressed with adapters and conformance tests; poor data quality with validation and freshness flags; forecast uncertainty with reserve margins and rolling updates; limited sensor energy with selective sampling; privacy risk with local processing and access controls; and optimizer failure with a tested fallback policy. Capital cost, commissioning effort, and user acceptance should be assessed alongside technical performance.

XIII. LIMITATIONS AND FUTURE WORK

This paper integrates concepts from four uploaded research papers but does not reproduce every method, equation, or experiment in those sources. Two additional uploaded PDFs titled “design” and “management” could not be text-extracted in the available processing, so their contents are not incorporated into the technical claims. The proposed framework is conceptual and has not been implemented or empirically validated here. The optimization model is deliberately simplified and does not include detailed AC power flow, inverter dynamics, voltage/frequency control, battery electrochemistry, or a complete cyber-security threat model.

Future work should implement the architecture in MATLAB/Simulink, Python, or a hardware-in-the-loop testbed; document the data and parameter assumptions; benchmark centralized, hierarchical, and distributed variants; and test under realistic outages and sensor failures. Research should also examine robust or stochastic optimization, forecast uncertainty, battery-health-aware control, privacy-preserving analytics, and methods for proving that adaptive sampling preserves critical event detection.

The first limitation is that the paper is a conceptual integration of literature rather than a field trial. No new household measurements, hardware prototype, or end-to-end experimental dataset is reported here, so the proposed system’s numerical performance remains unknown. The source papers also use different assumptions, system boundaries, and evaluation methods, which limits direct comparison across their results.

A second limitation is implementation dependence. Results may vary with PV and battery sizing, load flexibility, tariff design, weather, network reliability, local regulations, and the algorithms selected. Genetic algorithms can have variable runtime and may not guarantee a global optimum; forecasts can fail under unusual behavior or weather; and adaptive sensing can reduce information quality if thresholds are poorly chosen. These risks require explicit testing rather than assuming the modules combine without conflict.

Future work should build a reproducible simulation and hardware-in-the-loop platform, then test a limited live pilot where permitted. It should compare fixed and adaptive sensing, rule-based and optimization-based scheduling, and



centralized and hybrid control. Additional work should quantify uncertainty propagation from sensors to forecasts and schedules, examine battery ageing and lifecycle cost, test privacy-preserving analytics, and assess robustness under cyber incidents and communication outages.

Further research should define acceptance thresholds with stakeholders, include occupant comfort and user override in the objective, and report results across multiple sites rather than a single idealized profile. A useful next step is an open benchmark containing aligned PV, load, tariff, sensor-quality, and grid-status time series with documented equipment constraints. This would enable fairer comparisons and make negative as well as positive findings reproducible.

XIV. CONCLUSION

This paper has brought together four complementary research themes into one coherent design for smart home and microgrid energy management. Genetic optimization provides a mechanism for allocating PV, battery, and grid energy; microgrid research supplies the operational structure and constraints; big data analytics contributes data-quality and processing principles; and adaptive WSN methods offer a way to reduce sensing and communication energy without sacrificing required QoS. The proposed framework coordinates these functions through a feedback loop that validates measurements, forecasts generation and demand, adapts sensor operation, optimizes energy flows, and monitors results. Its performance remains a research question until evaluated against consistent baselines. A rigorous future study should therefore prioritize reproducibility, outage resilience, data integrity, battery constraints, and transparent reporting of both energy-system and sensor-network metrics.

The proposed architecture links data acquisition and validation, demand and PV forecasting, adaptive sensor management, constrained scheduling, and local safety supervision in a closed feedback loop. Its main design principle is to coordinate the energy plan with the quality and timeliness of the measurements that support it, while keeping critical protection independent of non-critical analytics.

The design is intended to be modular and scalable: a home can implement the core functions on a local gateway, while a larger microgrid can distribute analytics and coordination across multiple controllers. Practical deployment requires documented interfaces, consistent units and timestamps, secure communications, command validation, operator override, and tested fallback behavior.

In conclusion, the literature supports the relevance of the component techniques, while the benefits of their joint operation remain a hypothesis for future testing. A disciplined evaluation using common scenarios, explicit baselines, reliability and sensing metrics, and reproducible reporting is necessary before claiming quantified energy savings or improved sensor lifetime. This distinction keeps the research contribution technically useful without overstating evidence.

XV. ABBREVIATIONS AND KEY SYMBOLS

PV = photovoltaic; SOC = state of charge; BMS = battery-management system; GA = genetic algorithm; WSN = wireless sensor network; QoS = quality of service; DSM = demand-side management; MAE = mean absolute error; RMSE = root mean squared error.

$P_{pv,t}$ = available PV power at interval t ; $P_{load,t}$ = demand; $P_{bat,ch,t}$ and $P_{bat,dis,t}$ = battery charging and discharging power; $P_{grid,in,t}$ and $P_{grid,out,t}$ = grid import and export; $P_{short,t}$ = unmet demand; η_{ch} and η_{dis} = battery charge/discharge efficiencies; E_{bat} = nominal battery energy capacity.

The following abbreviations and symbols are used throughout the paper. Units and exact conventions should be kept consistent across equations, tables, simulations, and implementation. Where a symbol's definition depends on a model-specific convention, that convention should be stated explicitly in the relevant equation or experiment.



REFERENCES

- [1] S. F. Thabet, M. F. Ibrahim, and A. Abu-Samah, "Intelligent Home Energy Management System Based on Genetic Algorithm for Hybrid PV-Battery Operation Under On/Off-Grid Conditions," IEEE Access, vol. 13, pp. 208832–208843, 2025, doi: 10.1109/ACCESS.2025.3639963.
- [2] L. Ahmethodžić, M. Mušić, and S. Huseinbegović, "Microgrid Energy Management: Classification, Review and Challenges," CSEE Journal of Power and Energy Systems, vol. 9, no. 4, pp. 1425–1438, 2023, doi: 10.17775/CSEEJPES.2021.09150.
- [3] F. Amalina, I. A. T. Hashem, Z. H. Azizul, A. T. Fong, A. Firdaus, M. Imran, and N. B. Anuar, "Blending Big Data Analytics: Review on Challenges and a Recent Study," IEEE Access, vol. 8, pp. 3629–3645, 2020, doi: 10.1109/ACCESS.2019.2923270.
- [4] J. Kang, J. Kim, M. Kim, and M. Sohn, "Machine Learning-Based Energy-Saving Framework for Environmental States-Adaptive Wireless Sensor Network, IEEE Access, vol. 8, pp. 69359–69367, 2020, doi:10.1109/ACCESS.2020.29865 07.

