IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

Solid-State Transformer for Smart Distribution Networks, Renewable Energy Integration and Bidirectional Power Management

Pranjali M. Kawade[1], Rohit S. Jadhav[2], Raosaheb B. Yenape[3], Rohit S. Jadhav[4], Dr. Prashant Magadum[5]
[1,2,3,4]BMIT College of Engineering, Solapur, Maharashtra

Abstract: *The solid-state transformer (SST) is a power-electronic transformer architecture intended to extend the passive voltage-conversion function of a conventional transformer with controllablepower flow, voltage regulation and energy management capabilities. This paper presents an expanded design-oriented framework for a three-stage SST comprising a controlled medium-voltage AC/DC converter, an isolated medium-frequency DC/DC converter and a low-voltage AC/DC interface. The study examines SST operating principles, topology families, semiconductor selection, medium-frequency transformer design, control hierarchy, bidirectional power transfer, renewable-energy coupling, battery and electric-vehicle interfaces, power-quality functions, protection, thermal management and reliability. Analytical relations for voltage conversion, power balance, phase-shift control and efficiency are presented. A renewable-energy interface concept is developedarounda shared DC links othatphotovoltaic generation, battery storage, EV chargingandthe grid can exchange energy through independently controlled ports. The figures in this paper are original conceptual illustrations prepared for this manuscript; quantitative performance claimsare intentionally reservedfor future MATLAB/Simulink or hardware validationbytheauthors*

Keywords: Solid-state transformer, smart grid, medium-frequency transformer, dual-active bridge, Si C MOSFET, renewable energy, battery storage, EV charging, bidirectional power flow, power quality.

I. INTRODUCTION

Distribution networks are evolving from passive power-delivery systems toward active systems containing photovoltaic generators, batteries, electric vehicles, flexible loads and communication-assisted control. A conventional low-frequency transformer remains highly effective for voltage conversionandgalvanic isolation, but its magnetic ratioisessentially fixedanditcannot directly regulateactive or reactive power. SS Ts placecontrollable semiconductor convertersarounda medium-frequency isolation transformer, enabling severalgrid services within one conversion platform. Reviews in IEEE and other journals identify controllable bidirectional power flow, direct energy-storage integration, voltage regulation and power-quality support as major motivations for SST deployment [1]–[5].

II. RESEARCH MOTIVATION AND PROBLEM STATEMENT

The increasing penetration of distributed energy resources creates operating conditions in which power can flow in either direction and may fluctuate rapidly. A distribution transformer designed only forone-way power delivery does not inherently provide the control functions required for these conditions. The research problem addressed in this paper is how an SST architecture can combine voltage transformation, isolation and active power management while maintaining a practical control and protection structure.

The central design challenge is the trade-off among efficiency, controllability, power density, reliability, insulation stress, semiconductor switching frequency and cost. The SST should not be considered automatically superior to a

Copyright to IJARSCT
www.ijarsct.co.in
DOI: 10.48175/568

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

conventional transformer in every application; rather, its additional functions become valuable when controllability and multi-port energy integration are important.

III. SST ARCHITECTURE AND TOPOLOGIES

An SST can be realized with one or moreconversion stages. Single-stage approaches reduce the number of conversion blocks but can make high-voltage switching, isolation and control more demanding. Two-stage architectures reduce some complexity, while three-stage structures provide clear functional separation between grid-side AC/DC conversion, isolated DC/DC power transfer and low-voltage AC/DC conversion. The three-stage arrangement is selected here because it offers a natural common DC-link interface for renewable sources and storage.



Fig.1. Conceptual comparison of SST topology families.

IV. POWER CONVERSION STAGES

A. Medium-voltage AC/DC stage: The input converter performs active rectification, regulates the high-voltage DC link and shapes grid current. An asynchronousreference-frame controller canregulate d-axis and q-axis currents, allowingactive-power and reactive-power control.

B. Isolated DC/DC stage:A dual-active-bridge (DAB) converter is suitableforbidirectional power transfer. Two full bridges generate high-frequency square-wave voltages across a medium-frequency transformer. Phase shift between the bridges controls transferred power. Transformer leakage inductance actssasthemainpower-transfer element and cansupportsoft-switching operation.

C. Low-voltage interface: The final stage can synthesize a regulated AC waveform or provide a DC output. A DC interface is especially useful for EV chargers, batteriesand DC microgridsbecauseitavoidsunnecessaryconversion between DC and AC.

V. MEDIUM-FREQUENCY TRANSFORMER DESIGN

The medium-frequency transformer (MFT) providesgalvanic isolation and voltage adaptation whileoperating at a frequency much higher than the conventional50/60 Hz transformer. Increasing frequency reduces the magnetic core volumeforagivenvolt-second requirement, but higher frequency also increases core loss, winding proximity loss and insulation stress.

Important design variables include core material, flux density, turns ratio, winding arrangement, leakage inductance, insulation system, cooling method and parasitic capacitance. A practical MF Tshouldbedesigned together with the converter becauseleakage inductancecan be intentionally usedinthe DAB power-transfer path. The transformer therefore becomesanactive partofthe converter design rather than an isolated passive component.

VI. SEMICONDUCTOR DEVICE SELECTION

Silicon IGBTs havehistorically been usedinhigh-power converters, while silicon-carbide(SiC) MOSFETs areincreasingly attractive where high switching frequency, lower switching losses and high-temperature operation are

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

required. Wide-bandgap devices can support increased power density, but their faster switching transitions also increase electromagnetic interference and demand careful gate-drive and layout design. Device selectionshouldconsidervoltage rating, current rating, switching energy, conduction resistance, thermal impedance, short-circuit capability and cost.

A conservative engineering design should maintain appropriate electrical and thermal margins rather thanselecting devices solely from nominal voltage and current ratings.

VII. MATHEMATICAL MODEL

The overall steady-state power balance is P_in = P_out + P_loss,

and the conversion efficiency is

η_SST=P_out/P_in×100%.

For an ideal isolated DAB stage, the transferred power is controlled mainly by the phase displacement between the bridge voltages. Acommonly used simplified relation is

P≈(n V_1V_2)/(ω_s L_σ)•ϕ(1−|ϕ|/π),

wherenisthetransformerturns ratio, V1 and V2 are bridge DC voltages, Lσ is referredleakage inductance,ωsis switching angular frequency and ϕis the phase shift in radians. This equation is a design-level approximation; the exact power characteristic depends on modulation, dead time, device drops and parasitic elements.

For the magnetic component, the transformer turns relation is approximately N2/N1≈V2/V1after accounting for converter waveform utilization and losses. The practical design must additionally satisfy insulation, temperature-rise and flux-density limits.

VIII. CONTROL STRATEGY

The proposed control system is hierarchical. The outer supervisory layer determines power references according to grid demand, renewable generation and storage state. The middle layer regulates DC-link and output voltage. Inner loops control grid current and DAB phase shift. This arrangement reducesinteractionbetween fast-switching controlsandslowerenergy managementdecisions.

The grid-side converter can use d–q current control: the d-axis component primarily controls active power while the q-axis component can be used to regulate reactive power or power factor. The DAB controller changes phase shift to regulate power transfer. The output converter regulates AC voltage magnitude, frequency or DC voltage depending on the selected application.



Fig.3. Hierarchical SS Tcontrolconcept.

IX. RENEWABLE ENERGY AND ENERGY STORAGE INTEGRATION

A major advantage of SS Ts is the possibility of creating a shared controlled DC environment for photovoltaic generation, batteries and EV charging. The proposed conceptual interface in Fig. 5 allows power to flow from PV to the DC link, from the DC link to a battery, from the battery back to the DC link, and between the DC link and the utility.

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

During high solar generation, the supervisory controller can prioritize local load supply and battery charging before exporting excess energy. During low solar generation, battery discharge can support the load. If grid conditions require it, the SST can exchange active and reactive power with the utility. Such coordination can reduce the need for separate conversion equipment, although the actual benefit depends on the selected ratings and control strategy.



Bidirectional energy exchange through controlled dc-link interfaces

Fig.2. Proposed multi-port renewable/storage/grid energy interface.

X. POWER-QUALITY FUNCTIONS

Because the SST contains active converters, it can be designed to support functions normally provided by separate power-electronic compensators. These may include power-factor correction, reactive-power support, voltage regulation and mitigation of selected current disturbances. The convertercanalsorespondtovoltagedisturbanceswithin its current and voltage limits.

However, power-quality functionality must not be confused with unlimited fault protection. Semiconductor devices have short-circuit energy limits, so fast detection and coordinated isolation are necessary. The SST protection system should distinguish between temporary disturbances, overloads and severe faults.

XI. PROTECTION AND FAULT MANAGEMENT

Protection is a major difference between an SST and a passive transformer. Recommended protection layers include input over-current detection, DC-link over-voltage detection, semiconductor desaturation or short-circuit protection, transformer temperature monitoring, insulation monitoring and controlled shutdown.

A useful protection sequence is detection, gate blocking, energy-path isolation and controlled discharge of stored DC energy. Modular SSTs can potentially isolate a failed converter cell while keeping healthy modules operational, improving availability. Theprotection architecture must nevertheless be validated experimentally because converter faults can develop much faster than conventional transformer protection operates.

XII. THERMAL MANAGEMENT AND RELIABILITY

SST reliability is strongly influenced by semiconductor junction temperature, thermal cycling, capacitor lifetime and MFT temperature. Conduction and switching losses create heat in the semiconductor devices, while core and winding losses heat the MFT. Thermal design should therefore be performed together with electrical design.

Forced-air cooling can be suitable for lower power levels, whereas liquid cooling may be considered for compact high-power systems. Reliability-oriented design should minimizethermal cycling amplitude, provide adequateheat-transfer paths and monitor critical temperatures. Capacitors in the DC linkalsorequirecareful lifetime assessmentbecauseripplecurrentandtemperaturestrongly influence their aging.

XIII. COMPARISON WITH CONVENTIONAL TRANSFORMER

A conventional transformer has a mature construction, low control complexity and very high efficiency around its rated operating condition. SS Ts add controllability, multi-port interfacing and power-electronic functions but introduce switching losses, control complexity, EMI and additional failure mechanisms.

The most appropriate comparisonisthereforefunctional rather than simply based ontransformer efficiency. Forapplicationsneedingonly fixed voltage transformation and isolation, a conventional transformer may remain

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

preferable. For systems requiring bidirectional flow, DC integration, active voltage controlandrenewable/storage coordination, the additional SS Tfunctionalitycanjustifytheincreasedcomplexity.

XIV. APPLICATIONS

Potential applications include smart distribution substations, renewable-energy collection, battery energy-storage systems, EV fast-charging stations, railway traction, DC microgrids, data centers and hybrid AC/DC distribution networks. In EV charging, the SST can combine grid-side power-factor correction, isolationandregulated DC chargingwithinacoordinatedplatform. In microgrids, its controllable ports can connect sources and loadsoperating at different voltage levels.

Recentreviewsalsoidentifyactive-distribution-networkservicesandimprovedgridflexibilityasimportantareasof SS Tresearch[6],[7].

XV. DESIGN METHODOLOGY FOR MATLAB/SIMULINK VALIDATION

A publication-ready simulation can be organized in five stages. First, define the rated input voltage, output voltage, rated power, switching frequency and DC-link voltage. Second, select the semiconductor devices and MFT turns ratio. Third, implement the rectifier, DAB and inverter/DC-interface models. Fourth, add closed-loop controllers andprotection logic. Fifth, perform steady-state, load-step and bidirectional-power tests.

The principal recorded outputs should be input current THD, power factor, DC-link voltage error, output-voltage regulation, efficiency, semiconductor temperatureanddynamic settling time. Thesemeasurementsprovide a reproduciblebasisforthe Results sectionandshould be reported with actual simulation or laboratory data rather than illustrative values.

XVI. ORIGINAL DESIGN PROPOSAL

The distinctive design direction proposed in this manuscript is a coordinated multi-port SST in which the high-voltage DC link is treated as an energy-routing node rather than merely an intermediate conversion variable. The supervisory controller assigns operating priorities among renewable generation, storage, local DC loadsandthegrid, whiletheinner converter loopsmaintainelectricalconstraints.

This concept is intended as aresearchframeworkratherthanaclaimofexperimentallydemonstratednovelty. Itsnoveltyforafinal publication should be established by the authors through a defined topology, control algorithm, parameter set, simulation results and comparison against published approaches.

XVII. RESULTS AND DISCUSSION FRAMEWORK

The present document deliberatelydoesnotfabricatenumericalexperimentalresults. Instead, it defines themeasurements needed to validate the proposed system. Table II providesarecommendedtest matrix. The authors canpopulateitafter simulation or hardware testing.

A strong results section should show: (1) grid voltage and current, (2) DC-link voltage during load changes, (3) DAB primary and secondary bridge voltages,(4)output voltage,(5)bidirectional power response,(6)efficiency versus load, and(7)thermal behavior. Thisapproach makes the manuscript technically defensible and avoids presenting assumed values as measured facts.

XVIII. LIMITATIONS

The principal limitations are high converter cost, switching losses, complex protection, electromagnetic compatibility requirements, insulation design at high dv/dt, thermal management and the need for sophisticated control. Reliability is also more difficult to assess than for a passive transformer because the SS Tcontainsmanyactive semiconductor devicesandcontrol electronics. Theselimitationsshouldbeincludedin any practical cost-benefit evaluation.

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

XIX. FUTURE SCOPE

Future work should include a completeparameterized MATLAB/Simulink model, SiC-basedswitching comparison, optimized MFT design, soft-switching analysis, fault-tolerant modular operation, real-time hardware-in-the-loop testing and laboratory prototype validation. Additional work can investigate AI-assistedenergy management, digital-twin monitoring, predictive maintenance, grid-forming functionsand coordinated operation of multiple SS Ts in an active distribution network.

XX. CONCLUSION

An expanded three-stage SST framework has been presented for smart distribution and renewable-energy applications. The architecture combines active grid-side conversion, medium-frequency galvanic isolation and a controllable low-voltage interface. Beyond voltage transformation, the SS Tcanprovideacontrollableenergy-routing platformforphotovoltaic generation, storage, EV charging and grid services.

The key engineering requirement is to co-design the semiconductor stages, medium-frequency transformer, control system, thermal path and protection system. Themanuscriptprovides the theoreticalanddesignfoundationforthatwork, whileleavingquantitativeperformance claims to the authors' own simulation or experimental validation. This separation is important for a credible research publication and for demonstrating genuine contribution.

Table II. Recommended validation test matrix.

Test	Operating condition	Primary measurements
T1	No-load startup	DC-link overshoot, startup current
T2	25–100% load sweep	Efficiency, voltage regulation, temperature
T3	Step-load change	Settling time, DC-link deviation
T4	Reactive-power command	Power factor, q-axis current
T5	Reverse power flow	Battery/grid power response
T6	Renewable fluctuation	DC-link stability, energy routing
T7	Fault/protection test	Trip time, safe shutdown

REFERENCES

[1] X. She, A. Q. Huang, and R. Burgos, “Review of Solid-State Transformer Technologies and Their Application in Power Distribution Systems,”IEEE Journal of Emerging and Selected Topicsin Power Electronics, vol.1, no.3, pp.186–198,2013, doi:10.1109/JESTPE.2013.2277917.

[2] F. Ruiz, M. Liserre, M. N. Teodorescu, and others, “Surveying Solid-State Transformer Structures and Controls:Providing Highly Efficient and Controllable Power Flow in Distribution Grids,”IEEE Industrial Electronics Magazine, vol.14, no.1, pp.56–70,2020, doi:10.1109/MIE.2019.2950436.

[3] A. Q. Huang, “Solid-State Transformersfora Smarter, Flexible, and More Electrified Future Distribution System,”IEEE Industrial Electronics Magazine, vol.10, no. 2, pp. 16–25, 2016.

[4] M. A. Hannan et al., “State of the Art of Solid-State Transformers: Advanced Topologies, Implementation Issues, Recent Progress and Improvements,”IEEE Access, vol. 8, pp. 19113–19132, 2020, doi: 10.1109/ACCESS.2020.2967345.

[5] H. Shadfar, M. G. Pashakolaei, and A. A. Foroud, “Solid-state transformers:Anoverviewoftheconcept, topology, anditsapplicationsinthesmart grid,”International Transactions on Electrical Energy Systems, vol.31, no.9, e12996,2021, doi:10.1002/2050-7038.12996.

[6] F. Wald et al., “Applications and Services of Solid-State Transformers in Active Distribution Networks—A Critical Review,”IEEE Transactionson Smart Grid, vol. 16, no. 5, pp. 3615–3637, 2025, doi: 10.1109/TSG.2025.3574007.

IJARSCT
International Journal of Advanced Research in Science, Communication and Technology
International Open-Access, Double-Blind, Peer-Reviewed, Refereed, Multidisciplinary Online Journal
ISSN: 2581-9429
Volume 6, Issue 6, October 2026
Impact Factor: 8.2

[7] D. K. Mishra et al., "A review on solid-state transformer:Abreakthroughtechnologyfor futuresmartdistributiongrids,"International Journal of Electrical Power & Energy Systems, vol. 133, art. 107255, 2021, doi: 10.1016/j.ijepes.2021.107255.
[8] Solid State Transformers:A Review—Part I:Stages of Conversion and Topologies, Technologies, vol.13, no.2,74,2025.
[9] "Solid-State Transformers in Modern Distribution Grids:A Comprehensive Review of Principles, Topologies, Key Technologies, Applications, and Challenges," Electronics, vol. 15, no. 13, art. 2839, 2026.